

Logo
ISTITUTO GIORDANO
Qualità al plurale.

Istituto Giordano SpA
Tax Code/ABN Number 00 549 540 409 Company's Share Capital   880,000 Fully Paid-up
Administrative and Economical Inventory C/- Chamber of Commerce,
Industry, Handicrafts & Agriculture (Rimini) 156766
Register of Enterprises No. 00 549 540 409
Notified European Body No. 0407
Accreditations: SINCERT (057A and 0823)   SINAL (0021)   SIT (Multisite 20)

FIRE REACTION LAB
(Gatteo Branch Office)
Tel 0541 818582   Fax 0541 818074   reazionefuoco@giordano.it

TEST CERTIFICATE

Place and Date of Issue: Gatteo, 19/09/2007

Instructing Party: LAMINAM, SpA   Via Ghiarola Nuova, 258   41042 FIORANO MODENESE (Modena)

Attn Ms Stefania Dal Borgo   Fax: 0536 1844201

Test Subject: Fire classification system of building products and components based on reaction to fire test results according to UNI EN 13501   1: 2005 regulations

Product description (according to indications given by the Instructing party).

3mm thick Ceramic Slab with strengthening glass fibre at the back called LAM S

Regulation reference:

- UNI EN 13501   1: 2005  Fire classification system of building products and components   Part 1: Classification based on reaction to fire test results ;
- UNI EN 13238 April 2002  Reaction to fire tests for building products   Conditioning procedures and general rules for the choice of sub-layers ;
- UNI EN ISO 1716: 2005  Reaction to fire tests for building products   Assessment of calorific value .
- UNI EN 9239 - 1: 2006  Reaction to fire tests for floor coverings   Part 1: Assessment of fire behaviour using a radiating heat source ;

Test results

Based on the results achieved during the test, the product has been classified as a **ClassA2_n, s1** of reaction to fire.

The Test Technician
(Qualified Industrial Technician Maurizio Vincenzi)

Illegible Signature