

Logo
ISTITUTO GIORDANO
Qualità al plurale.

Istituto Giordano SpA
Tax Code/ABN Number 00 549 540 409 Company's Share Capital € 880,000 Fully Paid-up
Administrative and Economical Inventory C/- Chamber of Commerce,
Industry, Handicrafts & Agriculture (Rimini) 156766
Register of Enterprises No. 00 549 540 409
Notified European Body No. 0407
Accreditations: SINCERT (057A and 0823) ó SINAL (0021) ó SIT (Multisite 20)

FIRE REACTION LAB
(Gatteo Branch Office)
Tel 0541 818582 ó Fax 0541 818074 ó reazionealfuoco@giordano.it

TEST CERTIFICATE

Place and Date of Issue: Gatteo, 19/09/2007

Instructing Party: LAMINAM, SpA ó Via Ghiarola Nuova, 258 ó 41042 FIORANO MODENESE (Modena)

Attn Ms Stefania Dal Borgo ó Fax: 0536 1844201

Test Subject: Fire classification system of building products and components based on reaction to fire test results according to UNI EN 13501 ó 1: 2005 regulation

Product description (according to indications given by the Instructing party).

3mm thick Ceramic Slab with strengthening glass fibre at the back called LAMØS

Regulation reference:

- UNI EN 13501 ó 1: 2005 óFire classification system of building products and components ó Part 1: Classification based on reaction to fire test resultsö;
- UNI EN 13238 April 2002 óReaction to fire tests for building products ó Conditioning procedures and general rules for the choice of sub-layersö;
- UNI EN 13823: 2005 óReaction to fire tests for building products ó Building products, floor coverings subject to heat derived by a single combusting objectö;
- UNI EN ISO 1716: 2005 óReaction to fire tests for building products ó Assessment of calorific valueö;

Test results

Based on the results achieved during the test, the product has been classified as a **ClassA2, s1 – d 0** of reaction to fire.

The Test Technician
(Qualified Industrial Technician Maurizio Vincenzi)

Illegible Signature