

Emission Test Certificate

Monday March 31st, 2008

Supplier: Global Ventures Australia Pty Ltd (PO Box 186 Glenorie NSW 2157)

Sample Description: Eco-Core® Poplar Blockboard

Date Tested: March 2008

Test Method: EN717-2 (1995) "Wood-based Panels - Determination of Formaldehyde Release - Part 2: Formaldehyde Release by the Gas Analysis Method".

Emission Data:

Eco-Core® Poplar Blockboard	
Formaldehyde	0.08 mg/m ² /hr
This material based upon the emission rate quoted above can be assigned as E1 grade.	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV080217